



2018 Pavement Overlay Projects

DATE: August 31, 2018

ADDENDUM NO. 3

Addition/Change to the Contract Documents

The work provided for in this addendum shall become a part of the drawings and specifications for this project.

Question: Can the saw cut shown for the installation of the Street Side Concrete Curb (detail lower left of sheet 6) be less than 3 feet from the curb face so that there will be enough room to maintain 2 lanes of traffic during off hours?

Answer: Yes. The 3 feet of removal is not required if the contractor can perform the required work with less removal. The contractor is responsible for installing adequate protection along the road edge to protect traffic from driving/falling into the work zone.

This ADDENDUM shall be signed and attached to the Bidder's Proposal and shall subsequently become part of the Contract Documents.

Company Name	
Contractor Name	
Contractor Signature	
Date	