



408SS – Rock Creek Sanitary Trunk Line Upsizing Phase 1

DATE: April 13, 2021

BID ADDENDUM NO. 2

Addition/Change to the Contract Documents

The work provided for in this addendum shall become a part of the drawings and specifications for this project.

Question #1: Are Bid Items 19 and 20 for the material used in items 15, 16, 17 and 18?

Response: *Bid Items 19 and 20 are for the material used in Bid Items 15, 16, 17 and 18.*

Question #2: Regarding “S-36 Trench Compaction Testing”, having done the section of pipeline north of this project for CWS a few years ago which also had a compaction requirement, we found that due to the moisture content and variation of soils, testing native soils for compaction was not possible. The compaction testing requirement was waived on our contract. Just curious as to your thoughts regarding your requirements for this project if we encounter similar conditions?

Response: *In-situ soil conditions may warrant changes to compaction testing requirements/methods but this will not be known until construction/excavation begins. Compaction testing requirements will remain part of the bid submittal as specified.*

Question #3: For clearing operations, can chipped woody debris be utilized for erosion control and left onsite?

Response: *Bid the project per the contract documents. The use of wood chips as a value engineering proposed requires discussion and approval from the various permitting agencies.”*

Question #4: Will the city pay for any system development costs for the temp irrigation meter? Is there a link to costs if the contractor is required to provide?

Response: *The City will coordinate payment internally for any system development costs for obtaining the temporary irrigation meter (i.e., outside of the construction contract).*

This ADDENDUM shall be signed and attached to the Bidder’s Proposal and shall subsequently become part of the Contract Documents.

Company Name	
Contractor Name	
Contractor Signature	

Date	