

March 15, 2024

To: Potential bidders on the Cedar Creek Greenway Fence & Landscaping Restoration Project

From: Jason Waters, P.E., City Engineer, City of Sherwood

Re: Final Question & Answer Log

### Final Question & Answer Log

1. Can you provide the planholders list for this project?
  - a. You can find the planholder's list, as well as the pre-bid meeting sign-in sheet, on the bid web page here: <https://www.sherwoodoregon.gov/engineering/page/invitation-bid-cedar-creek-greenway-fence-improvements>.
2. Can alternate products be proposed that bidders believe to be equivalent or equal for the intended purpose?
  - a. Yes, and the following additional product has been pre-approved as an alternate product:
    - i. Dura-Crete S-Series (Heavy Duty Sound Walls): <https://dura-crete.net/sound-walls-2/>
    - ii. Dura-Crete Dry Cast S-Series (Aesthetic Screen Walls): <https://dura-crete.net/aesthetic-screen-walls-2/>
3. Can the wall heights and section widths between posts vary between 7' to 8' or do they have to be exactly 7' or 8' tall?
  - a. All dimensions may vary slightly depending upon the chosen product as long as the highest wall section doesn't exceed 8' above finished grade at the midpoint of each section. For example, a small portion of one section might be 6" below 7' height while another portion may be 8" over 7' and there may even be short sections a few inches over the 8' maximum height.
  - b. The goal is to provide the contractor with some flexibility to meet the intent of the project, while spanning root systems and underground utilities encountered along the way.
4. Is this intended to be a true Heavy Duty Sound Wall or an Aesthetic Screen Wall?
  - a. This is intended to be an "Aesthetic Screen Wall" with some inherent sound screening qualities.
  - b. There is NO sound dampening requirement or specification to meet, for example, submittals will not be checked against a minimum Sound Transmission Coefficient Rating,