



Woodhaven Park Phase 2

DATE: May 31, 2016

BID ADDENDUM NO. 4

Addition/Change to the Contract Documents

Question regarding Specification Section 1095.10(p) – Site Security and IT:

Under Access Control first bullet item states, “Provide Lenel branded and/or compatible (with City’s system) access control panel, power supplies, locksets, and reader.

Section bulleted items are replaced with the following:

Access controls shall include the following items:

- *One (1) Lenel LNL-AL400ULX cabinet and power supply*
- *One (1) Lenel LNL-2220 door controller*
- *One (1) Lenel LNL-XF1100D Reader (for plumbing chase door)*
- *Three (3) Von Duprin 6200 electronic strikes (2 for bathroom doors, and 1 for plumbing chase door)*
- *Provide cabling to support access control on the two bathroom doors and one plumbing chase door*
- *Bathroom doors and plumbing chase door will have electronic lock sets and be controlled via software and pre-set schedules*
- *Plumbing chase door will be activated by card reader and software*

This ADDENDUM shall be signed and attached to the Bidder’s Proposal and shall subsequently become part of the Contract Documents.

Company Name	
Contractor Name	
Contractor Signature	
Date	