Clean Water Services

MEMORANDUM

Date: October 2, 2013

To: Brad Kilby, Planning Manager, City of Sherwood

From: Jackie Sue Humphreys, Clean Water Services (the District)

Subject: Pacific Family Dental Parking Expansion, SP 13-01, 2S130CD01600, 2S131BA02100

Please include the following comments when writing your conditions of approval:

PRIOR TO ANY WORK ON THE SITE

A Clean Water Services (the District) Storm Water Connection Permit Authorization must be obtained. Application for the District's Permit Authorization must be in accordance with the requirements of the Design and Construction Standards, Resolution and Order No. 07-20, (or current R&O in effect at time of Engineering plan submittal), and is to include:

a. Detailed plans prepared in accordance with Chapter 2, Section 2.04.2.b-l.

b. Detailed grading and erosion control plan. An Erosion Control Permit will be required. Area of Disturbance must be clearly identified on submitted construction plans. If site area and any offsite improvements required for this development exceed one-acre of disturbance, project will require a 1200-CN Erosion Control Permit.

c. Detailed plans showing each lot within the development having direct access by gravity to public storm and sanitary sewer.

d. Provisions for water quality in accordance with the requirements of the above named design standards. Water Quality is required for all new development and redevelopment areas per R&O 07-20, Section 4.05.5, Table 4-1. Access shall be provided for maintenance of facility per R&O 07-20, Section 4.02.4.

e. If use of an existing, offsite or regional Water Quality Facility is proposed, it must be clearly identified on plans, showing its location, condition, capacity to treat this site and, any additional improvements and/or upgrades that may be needed to utilize that facility.

Exhibit D

2550 SW Hillsboro Highway • Hillsboro, Oregon 97123
Phone: (503) 681-3600 • Fax: (503) 681-3603 • cleanwaterservices.org

f. If private lot LIDA systems proposed, must comply with the current CWS Design and Construction Standards. A private maintenance agreement, for the proposed private lot LIDA systems, needs to be provided to the City for review and acceptance.

g. Show all existing and proposed easements on plans. Any required storm sewer, sanitary sewer, and water quality related easements must be granted to the City.

h. Site contains a "Sensitive Area." Applicant shall comply with the conditions as set forth in the Service Provider Letter No. 13-001610, dated July 1, 2013.

i. Clean Water Services shall require an easement over the Vegetated Corridor conveying storm and surface water management to Clean Water Services that would prevent the owner of the Vegetated Corridor from activities and uses inconsistent with the purpose of the corridor and any easements therein.

j. Detailed plans showing the sensitive area and corridor delineated, along with restoration and enhancement of the corridor.

k. Provide DSL and Corps of Engineers permits for any work in the wetlands or creek prior to any on site work, including grading and erosion control. Include permit number on cover sheet of plans or provide concurrence with the delineation.

l. Any proposed offsite construction activities will require an update or amendment to the current Service Provider Letter for this project.

CONCLUSION

This Land Use Review does not constitute the District's approval of storm or sanitary sewer compliance to the NPDES permit held by the District. The District, prior to issuance of any connection permits, must approve final construction plans and drainage calculations.