



NOTE:

INSTALLATION SHOWN IS ONLY A SUGGESTION. THE DISTANCE FROM BOTTOM OF DEVICE TO FINISH GRADE, FREEZE PROTECTION, AND CLEARANCE FOR TESTING & REPAIR ARE THE MAJOR CONSIDERATIONS FOR INSTALLATION. PLUGS TO BE INSTALLED IN TEST COCKS OF BELOW GROUND INSTALLATIONS (NO DISSIMILAR METALS).
IF FREEZE PROTECTION IS PROVIDED, THE 24" MIN CLEARANCE MAY BE REDUCED.



STANDARD DRAWING TITLE

1-1/2", 2", & 2-1/2" DOUBLE CHECK INSTALLATION

Any alteration of this drawing may not be associated in any way with the City of Sherwood Standard Drawings.

SCALE

N.T.S.

DRAWING NUMBER

W-73

DATE

JUL' 09