



PIPE SIZE	NO. OF PIPE RESTRAINED
4"	3 (54')
6"	3 (54')
8"	3 (54')
12"	4 (72')
16"	5 (90')

NOTES:

1. BACKFILL WILL BE COMPACTED 90% 3/4" GRAVEL, WITH MIN. 36" COVER
2. THREADED BRASS PIPING MAY BE USED IN PLACE OF COPPER TUBING
3. PROVIDE 24" SQUARE BY 4" THICK CONC. AROUND VALVE BOX OUTSIDE PAVED AREAS



STANDARD DRAWING TITLE

2" STANDARD BLOWOFF (FIELD-LOK)

Any alteration of this drawing may not be associated in any way with the City of Sherwood Standard Drawings.

SCALE

N.T.S.

DRAWING NUMBER

W-33

DATE

JUL' 09