



| QTY | DESCRIPTION | MATERIALS |
|-----|--|-----------|
| 1 | UTILITY VAULT 687 WA-763 WITH STAINLESS STEEL MANHOLE AND OSHA APPROVED LADDER WITH EXTERIOR TO BE SEALED WITH CRYSTAL SEAL OR APPROVED EQUAL | |
| 1 | 6" GATE VALVE FLG x MJ | |
| 1 | 6" GATE VALVE MJ | |
| 1 | 6" GATE VALVE FLG | |
| 1 | 6"x6" TEE MJ x FLG | |
| 1 | 6"x6" TEE MJ | |
| 2 | 6" W-42 MJ | |
| 8 | 6" NEALUS RETAINER GLANDS | |
| 1 | 6" SPOOL FLG PE 10 FT LG | |
| 1 | 6" SPOOL FLG PE 5 FT LG | |
| 1 | 6" DUCTILE IRON PIPE 30 LF | |
| 1 | OPTIONAL SUMP PUMP "GRINDFOS" MODEL "THE BOSS 200" 1/3 HP STAINLESS STEEL SUMP PUMP WITH 1/2" DISCHARGE SWITCH AND 1-1/4" DISCHARGE PIPING REFER TO DET W-42 & W-44 | |
| | MISC PIPING FOR DISCHARGE WITH INLINE CHECK VALVE | |

NOTES:

1. CONTRACTOR TO SEAL ALL OPENINGS IN VAULT WITH NON SHRINK GROUT
2. CONTRACTOR TO INSTALL CONCRETE CURB 3" TO 4" AROUND BASE OF VAULT IN AREAS WHERE FLOODING OR HIGH GROUND WATER EXIST
3. ALL MATERIALS SHALL BE AS NAMED OR EQUAL SUBMIT ALTERNATES FOR APPROVAL
4. THRUST BLOCK 1'-0" MIN THICKNESS



| | | |
|--|--------|----------------|
| STANDARD DRAWING TITLE | | DRAWING NUMBER |
| 6" x 3" MFM-MCT II METER INSTALLATION BY CONTRACTOR | | W-64 |
| Any alteration of this drawing may not be associated in any way with the City of Sherwood Standard Drawings. | SCALE | REVISION DATE |
| | N.T.S. | 2022.08.15 |