



1. CONTRACTOR TO SEAL ALL OPENINGS IN VAULT WITH NON SHRINK GROUT
2. CONTRACTOR TO INSTALL CONCRETE BALLAST 3" AROUND BASE OF VAULT IN AREAS WHERE FLOODING OR HIGH GROUND WATER EXIST
3. ALL MATERIALS SHALL BE AS NAMED OR EQUAL
SUBMIT ALTERNATES FOR APPROVAL
4. THRUST BLOCK 1'-0" MIN THICKNESS



JUL' 09