



NOTES:

1. THREADED BRASS PIPING MAY BE USED
IN PLACE OF COPPER TUBING
2. PROVIDE 24" SQUARE BY 4" THICK CONC.
AROUND VALVE BOX OUTSIDE PAVED AREAS



STANDARD DRAWING TITLE

RETROFIT 2" BLOWOFF OFF SIDE OF PIPE

Any alteration of this drawing may not be
associated in any way with the City of
Sherwood Standard Drawings.

SCALE

N.T.S.

DRAWING NUMBER

W-35

DATE

JUL' 09