



1. VALVE BOX NOT TO REST
ON OPERATING ASSEMBLY
2. OPERATOR EXTENSION
REQUIRED WHEN VALVE NUT
IS DEEPER THAN 3 FEET
FROM FINISHED GRADE
3. CENTER VALVE BOX ON
AXIS OF OPER NUT
4. PROVIDE 24" SQUARE BY 4" THICK
CONCRETE PAD AROUND VALVE
BOX OUTSIDE OF PAVED AREAS
5. VALVE BOX COVER SHALL BE A
MINIMUM OF 2½" IN LENGTH



STANDARD DRAWING TITLE

TYPICAL GATE VALVE SETTING DETAIL

Any alteration of this drawing may not be
associated in any way with the City of
Sherwood Standard Drawings.

SCALE

N.T.S.

DRAWING NUMBER

W-3

DATE

JUL' 09