



NOTES:

1. FOR 12" AND SMALLER WATER MAINS
2. VENT PIPING TO BE GALVANIZED
3. SLOPE COPPER TUBING FROM MAIN UP TO AIR VALVE 1% MIN
4. LOCATION SIMILAR TO METER BOX
SEE DETAIL W-7
5. SEE WATER SYSTEM STANDARDS FOR CORPORATION
STOPS, FLARE OR COMPRESSION AS SPECIFIED



STANDARD DRAWING TITLE

1" COMBINATION AIR & VACUUM VALVE

Any alteration of this drawing may not be associated in any way with the City of Sherwood Standard Drawings.

SCALE

N.T.S.

DRAWING NUMBER

W-50

DATE

JUL' 09