


USE TYTON JOINT-
"FIELD LOK" GASKETS
ON ADJACENT PIPE JOINTS
SEE TABLE

| PIPE SIZE | NO. OF PIPE RESTRAINED |
|-----------|------------------------|
| 4" | 3 (54') |
| 6" | 3 (54') |
| 8" | 3 (54') |
| 12" | 4 (72') |
| 16" | 5 (90') |

| | | | |
|---|---|--------|----------------|
|  | STANDARD DRAWING TITLE | | DRAWING NUMBER |
| | PHASE BREAK END | | W-32 |
| | <small>Any alteration of this drawing may not be associated in any way with the City of Sherwood Standard Drawings.</small> | SCALE | DATE |
| | | N.T.S. | JUL' 09 |