



## NOTES:

1. VALVE BOX NOT TO REST ON OPERATING ASSEMBLY.
2. OPERATOR EXTENSION REQUIRED WHEN VALVE NUT IS DEEPER THAN 3 FEET FROM FINISHED GRADE.
3. CENTER VALVE BOX ON AXIS OF OPER. NUT.
4. PROVIDE 24" SQUARE BY 4" THICK CONCRETE PAD OUTSIDE OF PAVED AREAS
5. VALVE BOX COVER SHALL BE A MINIMUM OF 2½" IN LENGTH



### STANDARD DRAWING TITLE

**BUTTERFLY VALVE SETTING DETAIL**

Any alteration of this drawing may not be associated in any way with the City of Sherwood Standard Drawings.

**SCALE**

**N.T.S.**

### DRAWING NUMBER

**W-4**

**DATE**

**JUL' 09**