


PLAN



PROFILE

NOTES:

1. DOUBLE CHECK VALVE BACKFLOW ASSEMBLY SHALL BE INSTALLED IN A LOCATION APPROVED BY THE CITY
2. DOUBLE CHECK VALVE BACKFLOW ASSEMBLY SHALL BE INSTALLED HORIZONTAL AND PLUMB
3. ALL CLEARANCES APPLY TO OUTSIDE, IN-BUILDING, AND VAULT INSTALLATIONS
4. INSULATE BLDG. AND/OR HAVE A HEAT SOURCE TO KEEP ENCLOSURE AT 40°F (NFPA 13-4-5.4.1.1)
5. ENCLOSURE SHALL INCLUDE A BORE SIGHTED DRAIN TO DAYLIGHT
6. 4" 3/4"-0" COMPACTED GRAVEL LEVELING COURSE
7. A DOOR OR OTHER APPROVED ACCESS SHALL BE PROVIDED
8. ALL ASSEMBLIES 3" AND LARGER SHALL BE FLANGED
9. ALL STRUCTURES TO COMPLY WITH LOCAL BUILDING CODES
10. FOR DCVA ON DOMESTIC ONLY SERVICE (NO FIRE SERVICE) NON-RISEING STEM VALVES ARE ACCEPTABLE



STANDARD DRAWING TITLE
DOUBLE CHECK VALVE ASSEMBLY CUSTOMER OWNED
(ABOVE GROUND) 3" THRU 10"

Any alteration of this drawing may not be associated in any way with the City of Sherwood Standard Drawings.

SCALE
N.T.S.

DRAWING NUMBER

W-74

DATE

JUL' 09