


NOTES:

1. THREADED BRASS PIPING MAY BE USED IN PLACE OF COPPER TUBING
2. PROVIDE 24" SQUARE BY 4" THICK CONC. AROUND VALVE BOX OUTSIDE PAVED AREAS

	STANDARD DRAWING TITLE		DRAWING NUMBER
	2" STANDARD BLOWOFF (THRUST BLOCK)		W-34
	Any alteration of this drawing may not be associated in any way with the City of Sherwood Standard Drawings.	SCALE	DATE
		N.T.S.	JUL' 09