



NOTES:

1. VENT PIPING TO BE GALVANIZED
2. SLOPE COPPER TUBE FROM MAIN UP TO AIR VALVE 1% MIN
3. LOCATION SIMILAR TO METER BOX
SEE DETAIL W-7
4. SEE WATER SYSTEM STDS FOR CORPORATION
STOPS, FLARE OR COMPRESSION, AS SPECIFIED



STANDARD DRAWING TITLE

2" COMBINATION AIR & VACUUM VALVE

Any alteration of this drawing may not be
associated in any way with the City of
Sherwood Standard Drawings.

SCALE

N.T.S.

DRAWING NUMBER

W-51

DATE

JUL' 09