



Home of the Tualatin River National Wildlife Refuge

## **SW Washington St Street & Utility Improvements Project**

DATE: February 13, 2026

**ADDENDUM NO. 1**

### Addition/Change to the Contract Documents

The work provided for in this addendum shall become a part of the drawings and specifications for this project.

1. The Bid Schedule (Base) has been revised to include:
  - a. New Bid Item 35 for Minor Adjustment of Manholes.
  - b. Removal of Bid Item for 6" PVC Sanitary Sewer Pipe.
  - c. Updated quantities for 4" PVC Sanitary Sewer Pipe, 3/4"-0 Aggregate Base, Level 2, 1/2-Inch ACP, Temporary, and Concrete Driveways.
2. Sheet 5 has been updated to show a shallow gas service crossing and to hand mix/till in the area within 2' of the gas line.
3. Sheet 6 has been updated to pothole the proposed storm lateral and gas main crossing.
4. Sheet 10 has been updated to include:
  - a. Sanitary Key Note S8 for minor adjustment of manholes.
  - b. Existing sanitary sewer manhole information.
  - c. Updated sanitary sewer lateral.
  - d. Removal of 6" sanitary sewer lateral replacement at SW Tualatin St.
  - e. Notes on abandoned gas main along SW Washington St between SW Tualatin St and SW Willamette St.
5. Sheet 11 has been updated to include additional 1' of concrete driveway removal.

### Attachments:

- SW Washington St Street & Utility Improvements Bid Plans - Addendum #1
- SW Washington St Street & Utility Improvements Bid Documents - Addendum #1

This ADDENDUM shall be signed and attached to the Bidder's Proposal and shall subsequently become part of the Contract Documents.

Company Name	
Contractor Name	
Contractor Signature	
Date	